

# 2019

## Drinking Water Quality Report



# Route 20

PWSID #6137120

# 2019 Drinking Water Quality Report

Rapidan Service Authority (RSA) is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you, the customer, about the water quality and services delivered to you every day. RSA's constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts made to continually improve the water treatment process and protect our water resources. RSA is committed to ensuring the quality of your water. This ground water source is a well located near Route 20 in Orange County.

## Your Drinking Water...

is ground water from two wells along Route 20. As water travels through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. Substances (referred to as contaminants) in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban storm water runoff, residential uses, and many other types of activities. Water from the two Route 20 wells is chlorinated to remove potentially harmful contaminants.

The Virginia Department of Health completed a source water assessment of this system in July 2002 which may be obtained by contacting RSA. The Route 20 Wells were determined to have a high susceptibility to contamination because of its location in an area that tends to promote migration of contaminants with land use activities of concern within the assessment area. While most ground water systems are vulnerable to contamination due to land use activities, no known contamination was discovered during the period of review.

## Protecting Your Water

Rapidan Service Authority employees are working around the clock to provide top quality water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. We also want to remind all of our customers to be aware of possible cross connections to the potable water system. A cross connection is a link between the potable water system and any non-potable source and can affect not only your home, it can affect the entire potable water supply. **If you think you have the possibility of a cross connection, please contact RSA immediately.**

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements, and must be approved by the RSA Board of Members following a public hearing.

RSA wants its valued customers to be informed about their water utility. If you have concerns to share with our Board, you may attend any of our regularly scheduled meetings. They are held, as needed, on the third Thursday of the month at 2:00 P.M. in various locations in the counties we serve - Orange, Madison, and Greene. Visit [rapidan.org/calendar-of-events](https://rapidan.org/calendar-of-events) for more details on meeting dates and locations.

If you have any questions about this report or your water utility, please contact **Timothy Clemons at (434) 985-7811.**

RSA routinely monitors for contaminants in the drinking water, in accordance with Federal and State regulations. The table on the next page shows the results of testing for the most recent monitoring period.

In this table you will find terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

- *Action Level (AL)*: the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- *Maximum Contaminant Level (MCL)*: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- *Maximum Contaminant Level Goal (MCLG)*: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- *Maximum Residual Disinfectant Level Goal (MRDLG)*: the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- *Maximum Residual Disinfectant Level (MRDL)*: the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants
- *Nephelometric Turbidity Unit (NTU)*: a measure of the clarity of water. Turbidity in excess of 5 NTUs is just noticeable to the average person.
- *Non-Detects (ND)*: laboratory analysis indicates that the constituent is not present.
- *Parts per million (ppm) or milligrams per liter (mg/l)*: one part per million corresponds to one minute in two years or a single penny in \$10,000.
- *Parts per billion (ppb) or micrograms per liter (ug/l)*: one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- *Picocuries per liter (pCi/l)*: a measure of radioactivity.
- *Treatment Technique (TT)*: A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Bracketed numbers represent the range of values detected.

WATER QUALITY RESULTS								
Detected Contaminant	Sampling Year	Violation	Level Detected/ Range	Units	MCLG	MCL	Likely Source of Contamination	
Microbiological Contaminants								
E-coli Bacteria	2019	No	0	Presence or absence	0	Routine and repeat samples are total coliform positive and one is E-coli positive	Human and animal fecal waste	
Chemical & Radiological Contaminants								
Alpha Particles	2016	No	2.15	Pci/L	0	15	Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation	
Barium	2019	No	0.0454	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
Beta Particles	2016	No	3.27	Pci/L	0	4 mrem/yr	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation	
Chromium	2019	No	0.0051	ppm	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits	
Nitrite + Nitrate	2019	No	0.26	ppm	10	10	Runoff from fertilizer use; leaching from septic systems; erosion of natural deposits	
Radium (-226 & -228)	2016	No	1.60	Pci/L	0	5	Erosion of natural deposits	
Disinfection By-Products, Precursors & Residuals								
Chlorine	2019	No	0.5 (0.2 – 1.0)	ppm	MRDLG =4	MRDL =4	Water additive used to control microbes	
Haloacetic Acids	2018	No	ND	ppb	N/A	60	By-product of disinfection	
Total Trihalomethanes	2018	No	6	ppb	N/A	80	By-product of chlorination	
Lead & Copper Contaminants		AL Exceeded?	Results of 90 <sup>th</sup> % Value	Units	MCLG	Action Level	# of Sample Sites Exceed AL	Likely Source of Contamination
Copper	2018	No	0.205	ppm	1.3	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits.
Lead	2018	No	1.4	ppb	0	15	0	Corrosion of household plumbing systems; erosion of natural deposits.



As you can see above, all tested contaminants fell below Maximum Contaminant Level limits in 2019.

In keeping with National Primary Drinking Water Regulations, we are obliged to inform you that we may be in violation of state regulations. During the 2017-2019 monitoring period, we did not test for Volatile Organic Compounds (VOCs) or Radiologicals, and therefore cannot be certain of compliance with State regulations for VOCs and Radiologicals. There is nothing you need to do at this time. We will collect the missed samples during the 2020-2022 monitoring period. Additionally, measures have been put into place to avoid future errors.

## Contaminants in Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards, EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Lead Education Statement

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rapidan Service Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Please call our office at (434) 985-7811 if you have questions regarding your water system.