

RAPIDAN SERVICE AUTHORITY

RT. 20 WATER SYSTEM

2018 Drinking Water Quality Report

PWSID #6137120

Rapidan Service Authority (RSA) is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you, the customer, about the water quality and services delivered to you every day. RSA's constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts made to continually improve the water treatment process and protect our water resources. RSA is committed to ensuring the quality of your water. This ground water source is a well located near Route 20 in Orange County.

The Virginia Department of Health completed a source water assessment of this system in July 2002 which may be obtained by contacting RSA. The Route 20 Well was determined to have a high susceptibility to contamination because of its location in an area that tends to promote migration of contaminants with land use activities of concern within the assessment area. While most ground water systems are vulnerable to contamination due to land use activities, no known contamination was discovered during the period of review.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. (5) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

RSA wants its valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the third Thursday of each month at 2:00 P.M. at various locations on a rotating basis in the counties we serve of Orange, Madison, and Greene. If you have any questions about this report or your water utility, please contact **Timothy L. Clemons at (434) 985-7811.**

RSA routinely monitors for constituents in the drinking water according to Federal and State regulations, but is not required to test for all contaminants every year. The following table shows the results of the most recent monitoring. In this table you will find terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL): the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG): the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is no convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Nephelometric Turbidity Unit (NTU): nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTUs is just noticeable to the average person.

Non-Detects (ND): laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or milligrams per liter (mg/l): one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or micrograms per liter (ug/l): one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/l): a measure of radioactivity.

Treatment Technique (TT): a required process intended to reduce the level of a contaminant in drinking water.

Bracketed numbers represent the range of values detected.

WATER QUALITY RESULTS								
Detected Contaminant	Sampling Year	Violation	Level Detected/Range	Units	MCLG	MCL	Likely Source of Contamination	
Chemical & Radiological Contaminants								
Total Coliform Bacteria	2018	No	0	Present/Absent	0		Naturally present in the environment	
Barium	2017	No	0.015	ppm	2	2	Erosion of natural deposits	
Nitrite + Nitrate	2018	No	0.314	ppm	10	10	Runoff from fertilizer use; leaching from septic systems; erosion of natural deposits	
Alpha Particles	2016	No	1.77	Pci/L	0	15	Erosion of natural deposits	
Gross Beta	2016	No	3.27	Pci/L	0		Erosion of natural deposits	
Combined Radium	2016	No	1.60	Pci/L	0	5	Erosion of natural deposits	
Chlorine	2018	No	0.5 (0.2 – 0.8)	ppm	MRDLG =4	MRDL =4	Water additive used to control microbes	
Haloacetic Acids	2018	No	ND	ppb	N/A	60	By-product of disinfection	
Total Trihalomethanes	2018	No	6	ppb	N/A	80	By-product of chlorination	
Lead & Copper Contaminants		AL Exceeded?	Results of 90th% Value	Units	MCLG	Action Level	# of Sample Sites Exceed AL	Likely Source of Contamination
Copper	2018	No	0.205	ppm	1.3	1.3	0	Corrosion of household plumbing systems
Lead	2018	No	1.4	ppb	0	15	0	Corrosion of household Plumbing systems

We are pleased to inform you that we had no detections of total coliform bacteria in our water in 2018.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rapidan Service Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791**.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

The employees at RSA work around the clock to provide top quality water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life and our children's future. We also want to remind all of our customers to be aware of possible cross connections to the potable water system. A cross connection is a link between the potable water system and any non-potable water source and can affect not only your home or business, it can affect the entire potable water system. If you think you have the possibility of a cross connection, please contact RSA immediately.

Please call RSA's office if you have questions regarding your water system.