

# 2021

## Drinking Water Quality Report



# Wilderness

PWSID #6137999

# 2021 Drinking Water Quality Report

Rapidan Service Authority (RSA) is pleased to present to you the 2021 Annual Water Quality Report. This report is designed to inform you, the customer, about the quality of water and services delivered to you every day. RSA's goal is to always provide you with a safe and dependable supply of drinking water. We want you to understand the efforts made to continually improve the water treatment process and protect our water resources. RSA is committed to ensuring the quality of your water.

## Your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes or reservoirs, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Substances (referred to as contaminants) in source water may include: (i) microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (ii) inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (iii) pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; (iv) organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and (v) radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Your drinking water comes from the Rapidan River. A source water assessment of the Rapidan River was completed by the Virginia Department of Health in May 2002 and may be obtained by contacting RSA. While all surface water sources are vulnerable to contamination due to changing atmospheric conditions and land use activities, no known contamination was discovered during the period of review.

Water from the Rapidan River is treated by RSA to not only meet State and Federal regulations, but also to be aesthetically pleasing for customers. Treatment includes oxidation using Sodium Permanganate, coagulation using Polyaluminum Chloride, flocculation, sedimentation, and filtration. Sodium Fluoride is then added to help promote strong teeth and prevent tooth decay. Next, Sodium Carbonate is used to adjust pH and prevent corrosion in the distribution system. Finally, chlorine is added to disinfect the water before heading to your tap. For more information on the treatment process, visit [rapidan.org/water-treatment-process](http://rapidan.org/water-treatment-process).

## Protecting Your Water

Rapidan Service Authority employees are working around the clock to provide top quality water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. We also want to remind all of our customers to be aware of possible cross connections to the potable water system. A cross connection is a link between the potable water system and any non-potable source and can affect not only your home, it can affect the entire potable water supply. **If you think you have the possibility of a cross connection, please contact RSA immediately.**

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements, and must be approved by the RSA Board of Members following a public hearing.

RSA wants its valued customers to be informed about their water utility. If you have concerns to share with our Board, you may attend any of our regularly scheduled meetings. They are held, as needed, on the third Thursday of the month at 2:00 P.M. in various locations in the counties we serve - Orange, Madison, and Greene. Visit [rapidan.org/calendar-of-events](http://rapidan.org/calendar-of-events) for more details on meeting dates and locations.

If you have any questions about this report or your water utility, please contact **David Jarrell at (434) 985-7811**.

## Definitions

To ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in the water provided by waterworks. The U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. RSA routinely monitors for contaminants in the drinking water, in accordance with Federal and State regulations. The table on the next two pages shows the results of testing for the most recent monitoring period. In this table you will find terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

- *Action Level (AL)*: the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- *Level 1 Assessment*: A Level 1 Assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
- *Level 2 Assessment*: A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E-coli MCL violation has occurred and / or why total coliform bacteria have been found in our water system on multiple occasions.
- *Maximum Contaminant Level (MCL)*: the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- *Maximum Contaminant Level Goal (MCLG)*: the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- *Maximum Residual Disinfectant Level Goal (MRDLG)*: the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- *Maximum Residual Disinfectant Level (MRDL)*: the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants
- *Nephelometric Turbidity Unit (NTU)*: a measure of the clarity of water. Turbidity in excess of 5 NTUs is just noticeable to the average person.
- *Non-Detects (ND)*: laboratory analysis indicates that the constituent is not present.
- *Parts per million (ppm) or milligrams per liter (mg/l)*: one part per million corresponds to one minute in two years or a single penny in \$10,000.
- *Parts per billion (ppb) or micrograms per liter (ug/l)*: one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- *Picocuries per liter (pCi/l)*: a measure of radioactivity.
- *Treatment Technique (TT)*: A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
- *Ultraviolet (UV)*: A treatment method to disinfect water using ultraviolet light.



## WATER QUALITY RESULTS

Detected Contaminant	Sampling Year	Violation	Level Detected/ Range	Units	MCLG	MCL	Likely Source of Contamination	
<b>Microbiological Contaminants</b>								
E-coli Bacteria	2021	No	0	Presence or absence	0	Routine and repeat samples are total coliform positive and one is E-coli positive	Human and animal fecal waste	
<b>Chemical &amp; Radiological Contaminants</b>								
Atrazine	2019	No	0.4	ppb	3	3	Herbicide runoff	
Barium	2021	No	0.0143	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
Fluoride	2021	No	0.67	ppm	4	4	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories	
Nitrite + Nitrate	2021	No	0.75	ppm	10	10	Runoff from fertilizer use; leaching from septic systems; erosion of natural deposits	
Turbidity % samples ≤0.3 NTU	2021	No No	0.29 100%	NTU %	N/A N/A	TT 95%	Soil runoff	
<b>Disinfection By-Products, Precursors &amp; Residuals</b>								
Chlorine	2021	No	1.2 (0.5 - 2)	ppm	MRDLG =4	MRDL =4	Water additive used to control microbes	
Total Organic Carbon	2021	No	RAA 1.125 (1.09 - 1.40)	Removal Ratio	N/A	TT	Naturally present in the environment	
Haloacetic Acids Site 1 Site 2 Site 3 Site 4	2021	No No No No	35 (19 - 42) 32 (19 - 38) 27 (17 - 33) 38 (19 - 51)	ppb	N/A	60	By-product of chlorination	
Total Trihalomethanes Site 1 Site 2 Site 3 Site 4	2021	No No No No	35 (27 - 49) 37 (26 - 48) 32 (21 - 45) 40 (26 - 62)	ppb	N/A	80	By-product of chlorination	
<b>Lead &amp; Copper Contaminants</b>	<b>Sampling Year</b>	<b>AL Exceeded?</b>	<b>Results of 90<sup>th</sup>% Value</b>	<b>Units</b>	<b>MCLG</b>	<b>Action Level</b>	<b># of Sample Sites Exceed AL</b>	<b>Likely Source of Contamination</b>
Lead	2020	No	6.32	ppb	0	15	0	Corrosion of household plumbing systems
Copper	2020	No	0.0664	ppm	1.3	1.3	0	Corrosion of household plumbing systems

## **Violation Information**

We were in full compliance with all water quality parameters, and no violations occurred during the calendar year in 2021.

## **Additional Health Information**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

MCL's are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards, EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## **Lead Education Statement**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home/building plumbing. RSA is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, then you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791).

The waterworks owners prepared this Drinking Water Quality Report with the assistance and approval of the Virginia Department of Health (VDH). Please call our office at (434) 985-7811 if you have questions regarding your water system.